

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/192/26	Model No.: KFARQ-6-50%	Date: 02-06-2026
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 192/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 19101 To 19200 And 19105A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 19105A and removed from the Lot/Batch							
19101	Pass	19102	Pass	19103	Pass	19104	Pass
19105	Pass	19106	Pass	19107	Pass	19108	Pass
19109	Pass	19110	Pass	19111	Pass	19112	Pass
19113	Pass	19114	Pass	19115	Pass	19116	Pass
19117	Pass	19118	Pass	19119	Pass	19120	Pass
19121	Pass	19122	Pass	19123	Pass	19124	Pass
19125	Pass	19126	Pass	19127	Pass	19128	Pass
19129	Pass	19130	Pass	19131	Pass	19132	Pass
19133	Pass	19134	Pass	19135	Pass	19136	Pass
19137	Pass	19138	Pass	19139	Pass	19140	Pass
19141	Pass	19142	Pass	19143	Pass	19144	Pass
19145	Pass	19146	Pass	19147	Pass	19148	Pass
19149	Pass	19150	Pass	19151	Pass	19152	Pass
19153	Pass	19154	Pass	19155	Pass	19156	Pass
19157	Pass	19158	Pass	19159	Pass	19160	Pass
19161	Pass	19162	Pass	19163	Pass	19164	Pass
19165	Pass	19166	Pass	19167	Pass	19168	Pass
19169	Pass	19170	Pass	19171	Pass	19172	Pass
19173	Pass	19174	Pass	19175	Pass	19176	Pass
19177	Pass	19178	Pass	19179	Pass	19180	Pass
19181	Pass	19182	Pass	19183	Pass	19184	Pass
19185	Pass	19186	Pass	19187	Pass	19188	Pass
19189	Pass	19190	Pass	19191	Pass	19192	Pass
19193	Pass	19194	Pass	19195	Pass	19196	Pass
19197	Pass	19198	Pass	19199	Pass	19200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory