

HYDRO PRESSURE TEST

TC No.: HPT/A6/M/RQ/008/26	Model No.: KFDMSRQ-6	Date: 14-05-2026
Type and Capacity of Extinguisher	: KFDMSRQ-6-Kanex D Type Metal SP Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFDMSRQ6 008/26	
Batch Quantity	: 21.00 Nos.	
Serial Numbers	: 00141 To 160 And 145A	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 145A and removed from the Lot/Batch							
141	Pass	142	Pass	143	Pass	144	Pass
145	Pass	146	Pass	147	Pass	148	Pass
149	Pass	150	Pass	151	Pass	152	Pass
153	Pass	154	Pass	155	Pass	156	Pass
157	Pass	158	Pass	159	Pass	160	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory