

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/143/26	Model No.: KFARQ-6-90%	Date: 09-06-2026
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 143/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 14201 To 14300 And 14205A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 14205A and removed from the Lot/Batch							
14201	Pass	14202	Pass	14203	Pass	14204	Pass
14205	Pass	14206	Pass	14207	Pass	14208	Pass
14209	Pass	14210	Pass	14211	Pass	14212	Pass
14213	Pass	14214	Pass	14215	Pass	14216	Pass
14217	Pass	14218	Pass	14219	Pass	14220	Pass
14221	Pass	14222	Pass	14223	Pass	14224	Pass
14225	Pass	14226	Pass	14227	Pass	14228	Pass
14229	Pass	14230	Pass	14231	Pass	14232	Pass
14233	Pass	14234	Pass	14235	Pass	14236	Pass
14237	Pass	14238	Pass	14239	Pass	14240	Pass
14241	Pass	14242	Pass	14243	Pass	14244	Pass
14245	Pass	14246	Pass	14247	Pass	14248	Pass
14249	Pass	14250	Pass	14251	Pass	14252	Pass
14253	Pass	14254	Pass	14255	Pass	14256	Pass
14257	Pass	14258	Pass	14259	Pass	14260	Pass
14261	Pass	14262	Pass	14263	Pass	14264	Pass
14265	Pass	14266	Pass	14267	Pass	14268	Pass
14269	Pass	14270	Pass	14271	Pass	14272	Pass
14273	Pass	14274	Pass	14275	Pass	14276	Pass
14277	Pass	14278	Pass	14279	Pass	14280	Pass
14281	Pass	14282	Pass	14283	Pass	14284	Pass
14285	Pass	14286	Pass	14287	Pass	14288	Pass
14289	Pass	14290	Pass	14291	Pass	14292	Pass
14293	Pass	14294	Pass	14295	Pass	14296	Pass
14297	Pass	14298	Pass	14299	Pass	14300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory