

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/FK/RQ/056/26	Model No.: KMCRQ-5-FK	Date: 27-05-2026
Type and Capacity of Extinguisher	: KMCRQ-5-FK-Kanex Clean Agent FK5112 Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5FK 056/26	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00551 To 560	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00551 To 560 and removed from the Lot/Batch							
551	Pass	552	Pass	553	Pass	554	Pass
555	Pass	556	Pass	557	Pass	558	Pass
559	Pass	560	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory