

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/238/26	Model No.: MARQ-6-50%	Date: 09-06-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 238/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 23701 To 23800 And 23705A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 23705A and removed from the Lot/Batch							
23701	Pass	23702	Pass	23703	Pass	23704	Pass
23705	Pass	23706	Pass	23707	Pass	23708	Pass
23709	Pass	23710	Pass	23711	Pass	23712	Pass
23713	Pass	23714	Pass	23715	Pass	23716	Pass
23717	Pass	23718	Pass	23719	Pass	23720	Pass
23721	Pass	23722	Pass	23723	Pass	23724	Pass
23725	Pass	23726	Pass	23727	Pass	23728	Pass
23729	Pass	23730	Pass	23731	Pass	23732	Pass
23733	Pass	23734	Pass	23735	Pass	23736	Pass
23737	Pass	23738	Pass	23739	Pass	23740	Pass
23741	Pass	23742	Pass	23743	Pass	23744	Pass
23745	Pass	23746	Pass	23747	Pass	23748	Pass
23749	Pass	23750	Pass	23751	Pass	23752	Pass
23753	Pass	23754	Pass	23755	Pass	23756	Pass
23757	Pass	23758	Pass	23759	Pass	23760	Pass
23761	Pass	23762	Pass	23763	Pass	23764	Pass
23765	Pass	23766	Pass	23767	Pass	23768	Pass
23769	Pass	23770	Pass	23771	Pass	23772	Pass
23773	Pass	23774	Pass	23775	Pass	23776	Pass
23777	Pass	23778	Pass	23779	Pass	23780	Pass
23781	Pass	23782	Pass	23783	Pass	23784	Pass
23785	Pass	23786	Pass	23787	Pass	23788	Pass
23789	Pass	23790	Pass	23791	Pass	23792	Pass
23793	Pass	23794	Pass	23795	Pass	23796	Pass
23797	Pass	23798	Pass	23799	Pass	23800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory