

HYDRO PRESSURE TEST

TC No.: HPT/F45/RQ/030/26	Model No.: KFMRQ-45	Date: 15-06-2026
Type and Capacity of Extinguisher	: KFMRQ-45-Kanex M Foam Trolley Mounted Fire Extinguisher Cap. 45 Ltr.	
Batch Number	: KFMRQ45 030/26	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 01451 To 1500	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on Cylinder Sr.No.1005A and which is removed from the batch (21st batch)							
1451	Pass	1452	Pass	1453	Pass	1454	Pass
1455	Pass	1456	Pass	1457	Pass	1458	Pass
1459	Pass	1460	Pass	1461	Pass	1462	Pass
1463	Pass	1464	Pass	1465	Pass	1466	Pass
1467	Pass	1468	Pass	1469	Pass	1470	Pass
1471	Pass	1472	Pass	1473	Pass	1474	Pass
1475	Pass	1476	Pass	1477	Pass	1478	Pass
1479	Pass	1480	Pass	1481	Pass	1482	Pass
1483	Pass	1484	Pass	1485	Pass	1486	Pass
1487	Pass	1488	Pass	1489	Pass	1490	Pass
1491	Pass	1492	Pass	1493	Pass	1494	Pass
1495	Pass	1496	Pass	1497	Pass	1498	Pass
1499	Pass	1500	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



Authorized Signatory