

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/032/26	Model No.: KMCRQ-10	Date: 27-03-2026
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 032/26	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00311 To 320	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00311 To 320 and removed from the Lot/Batch							
311	Pass	312	Pass	313	Pass	314	Pass
315	Pass	316	Pass	317	Pass	318	Pass
319	Pass	320	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory