

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/052/26	Model No.: KMCRQ-10	Date: 25-04-2026
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 052/26	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00511 To 520	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00511 To 520 and removed from the Lot/Batch							
511	Pass	512	Pass	513	Pass	514	Pass
515	Pass	516	Pass	517	Pass	518	Pass
519	Pass	520	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory