

HYDRO PRESSURE TEST

TC No.: HPT/F9/SP/HQ/020/26	Model No.: KFMSHQ-9-AR	Date: 26-06-2026
Type and Capacity of Extinguisher	: KFMSHQ-9-AR-Kanex AR-AFFF Foam Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: KFMSHQ9 020/26	
Batch Quantity	: 21.00 Nos.	
Serial Numbers	: 00381 To 400 And 385A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 385A and removed from the Lot/Batch							
381	Pass	382	Pass	383	Pass	384	Pass
385	Pass	386	Pass	387	Pass	388	Pass
389	Pass	390	Pass	391	Pass	392	Pass
393	Pass	394	Pass	395	Pass	396	Pass
397	Pass	398	Pass	399	Pass	400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory