

HYDRO PRESSURE TEST

TC No.: HPT/KF/LI/HQ2/008/26	Model No.: KFLIHQ-2	Date: 25-06-2026
Type and Capacity of Extinguisher	: KFLIHQ-2-Lithium-Ion (AVD) Stored Pressure Fire Extinguisher 2 Ltr	
Batch Number	: KFLIHQ2 008/26	
Batch Quantity	: 51.00 Nos.	
Serial Numbers	: 00351 To 400 And 355A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 355A and removed from the Lot/Batch							
351	Pass	352	Pass	353	Pass	354	Pass
355	Pass	356	Pass	357	Pass	358	Pass
359	Pass	360	Pass	361	Pass	362	Pass
363	Pass	364	Pass	365	Pass	366	Pass
367	Pass	368	Pass	369	Pass	370	Pass
371	Pass	372	Pass	373	Pass	374	Pass
375	Pass	376	Pass	377	Pass	378	Pass
379	Pass	380	Pass	381	Pass	382	Pass
383	Pass	384	Pass	385	Pass	386	Pass
387	Pass	388	Pass	389	Pass	390	Pass
391	Pass	392	Pass	393	Pass	394	Pass
395	Pass	396	Pass	397	Pass	398	Pass
399	Pass	400	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory