

HYDRO PRESSURE TEST

TC No.: HPT/MA9/A40/RQ/015/26	Model No.: MARQ-9-40%	Date: 22-06-2026
Type and Capacity of Extinguisher	: MARQ-9-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 9 Kg.	
Batch Number	: MARQ40%9 015/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 01401 To 1500 And 1405A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 1405A and removed from the Lot/Batch							
1401	Pass	1402	Pass	1403	Pass	1404	Pass
1405	Pass	1406	Pass	1407	Pass	1408	Pass
1409	Pass	1410	Pass	1411	Pass	1412	Pass
1413	Pass	1414	Pass	1415	Pass	1416	Pass
1417	Pass	1418	Pass	1419	Pass	1420	Pass
1421	Pass	1422	Pass	1423	Pass	1424	Pass
1425	Pass	1426	Pass	1427	Pass	1428	Pass
1429	Pass	1430	Pass	1431	Pass	1432	Pass
1433	Pass	1434	Pass	1435	Pass	1436	Pass
1437	Pass	1438	Pass	1439	Pass	1440	Pass
1441	Pass	1442	Pass	1443	Pass	1444	Pass
1445	Pass	1446	Pass	1447	Pass	1448	Pass
1449	Pass	1450	Pass	1451	Pass	1452	Pass
1453	Pass	1454	Pass	1455	Pass	1456	Pass
1457	Pass	1458	Pass	1459	Pass	1460	Pass
1461	Pass	1462	Pass	1463	Pass	1464	Pass
1465	Pass	1466	Pass	1467	Pass	1468	Pass
1469	Pass	1470	Pass	1471	Pass	1472	Pass
1473	Pass	1474	Pass	1475	Pass	1476	Pass
1477	Pass	1478	Pass	1479	Pass	1480	Pass
1481	Pass	1482	Pass	1483	Pass	1484	Pass
1485	Pass	1486	Pass	1487	Pass	1488	Pass
1489	Pass	1490	Pass	1491	Pass	1492	Pass
1493	Pass	1494	Pass	1495	Pass	1496	Pass
1497	Pass	1498	Pass	1499	Pass	1500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory