

HYDRO PRESSURE TEST

TC No.: HPT/A4/A50/RQ/036/26	Model No.: KFARQ-4-50%	Date: 03-04-2026
Type and Capacity of Extinguisher	: KFARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ50%4 036/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 03501 To 3600 And 3505A	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 3505A and removed from the Lot/Batch							
3501	Pass	3502	Pass	3503	Pass	3504	Pass
3505	Pass	3506	Pass	3507	Pass	3508	Pass
3509	Pass	3510	Pass	3511	Pass	3512	Pass
3513	Pass	3514	Pass	3515	Pass	3516	Pass
3517	Pass	3518	Pass	3519	Pass	3520	Pass
3521	Pass	3522	Pass	3523	Pass	3524	Pass
3525	Pass	3526	Pass	3527	Pass	3528	Pass
3529	Pass	3530	Pass	3531	Pass	3532	Pass
3533	Pass	3534	Pass	3535	Pass	3536	Pass
3537	Pass	3538	Pass	3539	Pass	3540	Pass
3541	Pass	3542	Pass	3543	Pass	3544	Pass
3545	Pass	3546	Pass	3547	Pass	3548	Pass
3549	Pass	3550	Pass	3551	Pass	3552	Pass
3553	Pass	3554	Pass	3555	Pass	3556	Pass
3557	Pass	3558	Pass	3559	Pass	3560	Pass
3561	Pass	3562	Pass	3563	Pass	3564	Pass
3565	Pass	3566	Pass	3567	Pass	3568	Pass
3569	Pass	3570	Pass	3571	Pass	3572	Pass
3573	Pass	3574	Pass	3575	Pass	3576	Pass
3577	Pass	3578	Pass	3579	Pass	3580	Pass
3581	Pass	3582	Pass	3583	Pass	3584	Pass
3585	Pass	3586	Pass	3587	Pass	3588	Pass
3589	Pass	3590	Pass	3591	Pass	3592	Pass
3593	Pass	3594	Pass	3595	Pass	3596	Pass
3597	Pass	3598	Pass	3599	Pass	3600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.


 SIHOR
 (GUJARAT)

Authorized Signatory