

HYDRO PRESSURE TEST

TC No.: HPT/A9/K/HQ/025/26	Model No.: KFKHQ-9	Date: 25-06-2026
Type and Capacity of Extinguisher	: KFKHQ-9-Kanex F Class Kitchen Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: KFKHQ9 025/26	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00241 To 250	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00241 To 250 and removed from the Lot/Batch							
241	Pass	242	Pass	243	Pass	244	Pass
245	Pass	246	Pass	247	Pass	248	Pass
249	Pass	250	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.

**Authorized Signatory**