

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/201/26	Model No.: KFARQ-6-50%	Date: 09-06-2026
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 201/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 20001 To 20100 And 20005A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 20005A and removed from the Lot/Batch							
20001	Pass	20002	Pass	20003	Pass	20004	Pass
20005	Pass	20006	Pass	20007	Pass	20008	Pass
20009	Pass	20010	Pass	20011	Pass	20012	Pass
20013	Pass	20014	Pass	20015	Pass	20016	Pass
20017	Pass	20018	Pass	20019	Pass	20020	Pass
20021	Pass	20022	Pass	20023	Pass	20024	Pass
20025	Pass	20026	Pass	20027	Pass	20028	Pass
20029	Pass	20030	Pass	20031	Pass	20032	Pass
20033	Pass	20034	Pass	20035	Pass	20036	Pass
20037	Pass	20038	Pass	20039	Pass	20040	Pass
20041	Pass	20042	Pass	20043	Pass	20044	Pass
20045	Pass	20046	Pass	20047	Pass	20048	Pass
20049	Pass	20050	Pass	20051	Pass	20052	Pass
20053	Pass	20054	Pass	20055	Pass	20056	Pass
20057	Pass	20058	Pass	20059	Pass	20060	Pass
20061	Pass	20062	Pass	20063	Pass	20064	Pass
20065	Pass	20066	Pass	20067	Pass	20068	Pass
20069	Pass	20070	Pass	20071	Pass	20072	Pass
20073	Pass	20074	Pass	20075	Pass	20076	Pass
20077	Pass	20078	Pass	20079	Pass	20080	Pass
20081	Pass	20082	Pass	20083	Pass	20084	Pass
20085	Pass	20086	Pass	20087	Pass	20088	Pass
20089	Pass	20090	Pass	20091	Pass	20092	Pass
20093	Pass	20094	Pass	20095	Pass	20096	Pass
20097	Pass	20098	Pass	20099	Pass	20100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory