

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/240/26	Model No.: MARQ-6-50%	Date: 09-06-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 240/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 23901 To 24000 And 23905A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 23905A and removed from the Lot/Batch							
23901	Pass	23902	Pass	23903	Pass	23904	Pass
23905	Pass	23906	Pass	23907	Pass	23908	Pass
23909	Pass	23910	Pass	23911	Pass	23912	Pass
23913	Pass	23914	Pass	23915	Pass	23916	Pass
23917	Pass	23918	Pass	23919	Pass	23920	Pass
23921	Pass	23922	Pass	23923	Pass	23924	Pass
23925	Pass	23926	Pass	23927	Pass	23928	Pass
23929	Pass	23930	Pass	23931	Pass	23932	Pass
23933	Pass	23934	Pass	23935	Pass	23936	Pass
23937	Pass	23938	Pass	23939	Pass	23940	Pass
23941	Pass	23942	Pass	23943	Pass	23944	Pass
23945	Pass	23946	Pass	23947	Pass	23948	Pass
23949	Pass	23950	Pass	23951	Pass	23952	Pass
23953	Pass	23954	Pass	23955	Pass	23956	Pass
23957	Pass	23958	Pass	23959	Pass	23960	Pass
23961	Pass	23962	Pass	23963	Pass	23964	Pass
23965	Pass	23966	Pass	23967	Pass	23968	Pass
23969	Pass	23970	Pass	23971	Pass	23972	Pass
23973	Pass	23974	Pass	23975	Pass	23976	Pass
23977	Pass	23978	Pass	23979	Pass	23980	Pass
23981	Pass	23982	Pass	23983	Pass	23984	Pass
23985	Pass	23986	Pass	23987	Pass	23988	Pass
23989	Pass	23990	Pass	23991	Pass	23992	Pass
23993	Pass	23994	Pass	23995	Pass	23996	Pass
23997	Pass	23998	Pass	23999	Pass	24000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory