

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/250/26	Model No.: MARQ-6-50%	Date: 15-06-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 250/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 24901 To 25000 And 24905A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 24905A and removed from the Lot/Batch							
24901	Pass	24902	Pass	24903	Pass	24904	Pass
24905	Pass	24906	Pass	24907	Pass	24908	Pass
24909	Pass	24910	Pass	24911	Pass	24912	Pass
24913	Pass	24914	Pass	24915	Pass	24916	Pass
24917	Pass	24918	Pass	24919	Pass	24920	Pass
24921	Pass	24922	Pass	24923	Pass	24924	Pass
24925	Pass	24926	Pass	24927	Pass	24928	Pass
24929	Pass	24930	Pass	24931	Pass	24932	Pass
24933	Pass	24934	Pass	24935	Pass	24936	Pass
24937	Pass	24938	Pass	24939	Pass	24940	Pass
24941	Pass	24942	Pass	24943	Pass	24944	Pass
24945	Pass	24946	Pass	24947	Pass	24948	Pass
24949	Pass	24950	Pass	24951	Pass	24952	Pass
24953	Pass	24954	Pass	24955	Pass	24956	Pass
24957	Pass	24958	Pass	24959	Pass	24960	Pass
24961	Pass	24962	Pass	24963	Pass	24964	Pass
24965	Pass	24966	Pass	24967	Pass	24968	Pass
24969	Pass	24970	Pass	24971	Pass	24972	Pass
24973	Pass	24974	Pass	24975	Pass	24976	Pass
24977	Pass	24978	Pass	24979	Pass	24980	Pass
24981	Pass	24982	Pass	24983	Pass	24984	Pass
24985	Pass	24986	Pass	24987	Pass	24988	Pass
24989	Pass	24990	Pass	24991	Pass	24992	Pass
24993	Pass	24994	Pass	24995	Pass	24996	Pass
24997	Pass	24998	Pass	24999	Pass	25000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory