

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/MA6/A50/RQ/053/26     | Model No.: MARQ-4-50%                                          | Date: 23-06-2026 |
| Type and Capacity of Extinguisher | : MARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg. |                  |
| Batch Number                      | : MARQ50%4 053/26                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                  |                  |
| Serial Numbers                    | : 05201 To 5300 And 5205A                                      |                  |
| Month of Manufacturing            | : Jun/26                                                       |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 5205A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 5201                                                         | Pass   | 5202     | Pass   | 5203     | Pass   | 5204     | Pass   |
| 5205                                                         | Pass   | 5206     | Pass   | 5207     | Pass   | 5208     | Pass   |
| 5209                                                         | Pass   | 5210     | Pass   | 5211     | Pass   | 5212     | Pass   |
| 5213                                                         | Pass   | 5214     | Pass   | 5215     | Pass   | 5216     | Pass   |
| 5217                                                         | Pass   | 5218     | Pass   | 5219     | Pass   | 5220     | Pass   |
| 5221                                                         | Pass   | 5222     | Pass   | 5223     | Pass   | 5224     | Pass   |
| 5225                                                         | Pass   | 5226     | Pass   | 5227     | Pass   | 5228     | Pass   |
| 5229                                                         | Pass   | 5230     | Pass   | 5231     | Pass   | 5232     | Pass   |
| 5233                                                         | Pass   | 5234     | Pass   | 5235     | Pass   | 5236     | Pass   |
| 5237                                                         | Pass   | 5238     | Pass   | 5239     | Pass   | 5240     | Pass   |
| 5241                                                         | Pass   | 5242     | Pass   | 5243     | Pass   | 5244     | Pass   |
| 5245                                                         | Pass   | 5246     | Pass   | 5247     | Pass   | 5248     | Pass   |
| 5249                                                         | Pass   | 5250     | Pass   | 5251     | Pass   | 5252     | Pass   |
| 5253                                                         | Pass   | 5254     | Pass   | 5255     | Pass   | 5256     | Pass   |
| 5257                                                         | Pass   | 5258     | Pass   | 5259     | Pass   | 5260     | Pass   |
| 5261                                                         | Pass   | 5262     | Pass   | 5263     | Pass   | 5264     | Pass   |
| 5265                                                         | Pass   | 5266     | Pass   | 5267     | Pass   | 5268     | Pass   |
| 5269                                                         | Pass   | 5270     | Pass   | 5271     | Pass   | 5272     | Pass   |
| 5273                                                         | Pass   | 5274     | Pass   | 5275     | Pass   | 5276     | Pass   |
| 5277                                                         | Pass   | 5278     | Pass   | 5279     | Pass   | 5280     | Pass   |
| 5281                                                         | Pass   | 5282     | Pass   | 5283     | Pass   | 5284     | Pass   |
| 5285                                                         | Pass   | 5286     | Pass   | 5287     | Pass   | 5288     | Pass   |
| 5289                                                         | Pass   | 5290     | Pass   | 5291     | Pass   | 5292     | Pass   |
| 5293                                                         | Pass   | 5294     | Pass   | 5295     | Pass   | 5296     | Pass   |
| 5297                                                         | Pass   | 5298     | Pass   | 5299     | Pass   | 5300     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



SIHOR  
(GUJARAT)

**Authorized Signatory**