

HYDRO PRESSURE TEST

TC No.: HPT/F45/RQ/032/26	Model No.: KFMRQ-45	Date: 26-06-2026
Type and Capacity of Extinguisher	: KFMRQ-45-Kanex M Foam Trolley Mounted Fire Extinguisher Cap. 45 Ltr.	
Batch Number	: KFMRQ45 032/26	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 01551 To 1600	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on Cylinder Sr.No.1505A and which is removed from the batch (31st batch)							
1551	Pass	1552	Pass	1553	Pass	1554	Pass
1555	Pass	1556	Pass	1557	Pass	1558	Pass
1559	Pass	1560	Pass	1561	Pass	1562	Pass
1563	Pass	1564	Pass	1565	Pass	1566	Pass
1567	Pass	1568	Pass	1569	Pass	1570	Pass
1571	Pass	1572	Pass	1573	Pass	1574	Pass
1575	Pass	1576	Pass	1577	Pass	1578	Pass
1579	Pass	1580	Pass	1581	Pass	1582	Pass
1583	Pass	1584	Pass	1585	Pass	1586	Pass
1587	Pass	1588	Pass	1589	Pass	1590	Pass
1591	Pass	1592	Pass	1593	Pass	1594	Pass
1595	Pass	1596	Pass	1597	Pass	1598	Pass
1599	Pass	1600	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



Authorized Signatory