

HELIUM LEAK DETECTION TEST

TC No.: HLD/A3/K/HQ/007/26

Model No.: KFKHQ-3

Date: 04-05-2026

Type and Capacity of Extinguisher : KFKHQ-3-Kanex F Class Kitchen Fire Extinguisher Cap. 3 Ltr.

Batch Number : KFKHQ3 007/26

Batch Quantity : 10 Nos.

Serial Numbers : 00061 To 70

Month of Manufacturing : May/26

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
61	Pass	62	Pass	63	Pass	64	Pass
65	Pass	66	Pass	67	Pass	68	Pass
69	Pass	70	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**