

HYDRO PRESSURE TEST

TC No.: HPT/A3/K/HQ/008/26	Model No.: KFKHQ-3	Date: 16-05-2026
Type and Capacity of Extinguisher	: KFKHQ-3-Kanex F Class Kitchen Fire Extinguisher Cap. 3 Ltr.	
Batch Number	: KFKHQ3 008/26	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00071 To 80 And 75A	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 75A and removed from the Lot/Batch							
71	Pass	72	Pass	73	Pass	74	Pass
75	Pass	76	Pass	77	Pass	78	Pass
79	Pass	80	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory