

HYDRO PRESSURE TEST

TC No.: HPT/F9/SP/RQ/041/26	Model No.: KFMSRQ-9	Date: 22-06-2026
Type and Capacity of Extinguisher	: KFMSRQ-9-Kanex M Foam SP Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: KFMSRQ9 041/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 04001 To 4100 And 4005A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 4005A and removed from the Lot/Batch							
4001	Pass	4002	Pass	4003	Pass	4004	Pass
4005	Pass	4006	Pass	4007	Pass	4008	Pass
4009	Pass	4010	Pass	4011	Pass	4012	Pass
4013	Pass	4014	Pass	4015	Pass	4016	Pass
4017	Pass	4018	Pass	4019	Pass	4020	Pass
4021	Pass	4022	Pass	4023	Pass	4024	Pass
4025	Pass	4026	Pass	4027	Pass	4028	Pass
4029	Pass	4030	Pass	4031	Pass	4032	Pass
4033	Pass	4034	Pass	4035	Pass	4036	Pass
4037	Pass	4038	Pass	4039	Pass	4040	Pass
4041	Pass	4042	Pass	4043	Pass	4044	Pass
4045	Pass	4046	Pass	4047	Pass	4048	Pass
4049	Pass	4050	Pass	4051	Pass	4052	Pass
4053	Pass	4054	Pass	4055	Pass	4056	Pass
4057	Pass	4058	Pass	4059	Pass	4060	Pass
4061	Pass	4062	Pass	4063	Pass	4064	Pass
4065	Pass	4066	Pass	4067	Pass	4068	Pass
4069	Pass	4070	Pass	4071	Pass	4072	Pass
4073	Pass	4074	Pass	4075	Pass	4076	Pass
4077	Pass	4078	Pass	4079	Pass	4080	Pass
4081	Pass	4082	Pass	4083	Pass	4084	Pass
4085	Pass	4086	Pass	4087	Pass	4088	Pass
4089	Pass	4090	Pass	4091	Pass	4092	Pass
4093	Pass	4094	Pass	4095	Pass	4096	Pass
4097	Pass	4098	Pass	4099	Pass	4100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory