

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/166/26	Model No.: KFARQ-6-90%	Date: 26-06-2026
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 166/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 16501 To 16600 And 16505A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 16505A and removed from the Lot/Batch							
16501	Pass	16502	Pass	16503	Pass	16504	Pass
16505	Pass	16506	Pass	16507	Pass	16508	Pass
16509	Pass	16510	Pass	16511	Pass	16512	Pass
16513	Pass	16514	Pass	16515	Pass	16516	Pass
16517	Pass	16518	Pass	16519	Pass	16520	Pass
16521	Pass	16522	Pass	16523	Pass	16524	Pass
16525	Pass	16526	Pass	16527	Pass	16528	Pass
16529	Pass	16530	Pass	16531	Pass	16532	Pass
16533	Pass	16534	Pass	16535	Pass	16536	Pass
16537	Pass	16538	Pass	16539	Pass	16540	Pass
16541	Pass	16542	Pass	16543	Pass	16544	Pass
16545	Pass	16546	Pass	16547	Pass	16548	Pass
16549	Pass	16550	Pass	16551	Pass	16552	Pass
16553	Pass	16554	Pass	16555	Pass	16556	Pass
16557	Pass	16558	Pass	16559	Pass	16560	Pass
16561	Pass	16562	Pass	16563	Pass	16564	Pass
16565	Pass	16566	Pass	16567	Pass	16568	Pass
16569	Pass	16570	Pass	16571	Pass	16572	Pass
16573	Pass	16574	Pass	16575	Pass	16576	Pass
16577	Pass	16578	Pass	16579	Pass	16580	Pass
16581	Pass	16582	Pass	16583	Pass	16584	Pass
16585	Pass	16586	Pass	16587	Pass	16588	Pass
16589	Pass	16590	Pass	16591	Pass	16592	Pass
16593	Pass	16594	Pass	16595	Pass	16596	Pass
16597	Pass	16598	Pass	16599	Pass	16600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



SIHOR
(GUJARAT)

Authorized Signatory