

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/140/26	Model No.: KFARQ-6-90%	Date: 27-05-2026
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 140/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 13901 To 14000 And 13905A	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 13905A and removed from the Lot/Batch							
13901	Pass	13902	Pass	13903	Pass	13904	Pass
13905	Pass	13906	Pass	13907	Pass	13908	Pass
13909	Pass	13910	Pass	13911	Pass	13912	Pass
13913	Pass	13914	Pass	13915	Pass	13916	Pass
13917	Pass	13918	Pass	13919	Pass	13920	Pass
13921	Pass	13922	Pass	13923	Pass	13924	Pass
13925	Pass	13926	Pass	13927	Pass	13928	Pass
13929	Pass	13930	Pass	13931	Pass	13932	Pass
13933	Pass	13934	Pass	13935	Pass	13936	Pass
13937	Pass	13938	Pass	13939	Pass	13940	Pass
13941	Pass	13942	Pass	13943	Pass	13944	Pass
13945	Pass	13946	Pass	13947	Pass	13948	Pass
13949	Pass	13950	Pass	13951	Pass	13952	Pass
13953	Pass	13954	Pass	13955	Pass	13956	Pass
13957	Pass	13958	Pass	13959	Pass	13960	Pass
13961	Pass	13962	Pass	13963	Pass	13964	Pass
13965	Pass	13966	Pass	13967	Pass	13968	Pass
13969	Pass	13970	Pass	13971	Pass	13972	Pass
13973	Pass	13974	Pass	13975	Pass	13976	Pass
13977	Pass	13978	Pass	13979	Pass	13980	Pass
13981	Pass	13982	Pass	13983	Pass	13984	Pass
13985	Pass	13986	Pass	13987	Pass	13988	Pass
13989	Pass	13990	Pass	13991	Pass	13992	Pass
13993	Pass	13994	Pass	13995	Pass	13996	Pass
13997	Pass	13998	Pass	13999	Pass	14000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory