

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/135/26	Model No.: KFARQ-6-90%	Date: 25-05-2026
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 135/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 13401 To 13500 And 13405A	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 13405A and removed from the Lot/Batch							
13401	Pass	13402	Pass	13403	Pass	13404	Pass
13405	Pass	13406	Pass	13407	Pass	13408	Pass
13409	Pass	13410	Pass	13411	Pass	13412	Pass
13413	Pass	13414	Pass	13415	Pass	13416	Pass
13417	Pass	13418	Pass	13419	Pass	13420	Pass
13421	Pass	13422	Pass	13423	Pass	13424	Pass
13425	Pass	13426	Pass	13427	Pass	13428	Pass
13429	Pass	13430	Pass	13431	Pass	13432	Pass
13433	Pass	13434	Pass	13435	Pass	13436	Pass
13437	Pass	13438	Pass	13439	Pass	13440	Pass
13441	Pass	13442	Pass	13443	Pass	13444	Pass
13445	Pass	13446	Pass	13447	Pass	13448	Pass
13449	Pass	13450	Pass	13451	Pass	13452	Pass
13453	Pass	13454	Pass	13455	Pass	13456	Pass
13457	Pass	13458	Pass	13459	Pass	13460	Pass
13461	Pass	13462	Pass	13463	Pass	13464	Pass
13465	Pass	13466	Pass	13467	Pass	13468	Pass
13469	Pass	13470	Pass	13471	Pass	13472	Pass
13473	Pass	13474	Pass	13475	Pass	13476	Pass
13477	Pass	13478	Pass	13479	Pass	13480	Pass
13481	Pass	13482	Pass	13483	Pass	13484	Pass
13485	Pass	13486	Pass	13487	Pass	13488	Pass
13489	Pass	13490	Pass	13491	Pass	13492	Pass
13493	Pass	13494	Pass	13495	Pass	13496	Pass
13497	Pass	13498	Pass	13499	Pass	13500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory