

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/248/26	Model No.: MARQ-6-50%	Date: 12-06-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 248/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 24701 To 24800 And 24705A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 24705A and removed from the Lot/Batch							
24701	Pass	24702	Pass	24703	Pass	24704	Pass
24705	Pass	24706	Pass	24707	Pass	24708	Pass
24709	Pass	24710	Pass	24711	Pass	24712	Pass
24713	Pass	24714	Pass	24715	Pass	24716	Pass
24717	Pass	24718	Pass	24719	Pass	24720	Pass
24721	Pass	24722	Pass	24723	Pass	24724	Pass
24725	Pass	24726	Pass	24727	Pass	24728	Pass
24729	Pass	24730	Pass	24731	Pass	24732	Pass
24733	Pass	24734	Pass	24735	Pass	24736	Pass
24737	Pass	24738	Pass	24739	Pass	24740	Pass
24741	Pass	24742	Pass	24743	Pass	24744	Pass
24745	Pass	24746	Pass	24747	Pass	24748	Pass
24749	Pass	24750	Pass	24751	Pass	24752	Pass
24753	Pass	24754	Pass	24755	Pass	24756	Pass
24757	Pass	24758	Pass	24759	Pass	24760	Pass
24761	Pass	24762	Pass	24763	Pass	24764	Pass
24765	Pass	24766	Pass	24767	Pass	24768	Pass
24769	Pass	24770	Pass	24771	Pass	24772	Pass
24773	Pass	24774	Pass	24775	Pass	24776	Pass
24777	Pass	24778	Pass	24779	Pass	24780	Pass
24781	Pass	24782	Pass	24783	Pass	24784	Pass
24785	Pass	24786	Pass	24787	Pass	24788	Pass
24789	Pass	24790	Pass	24791	Pass	24792	Pass
24793	Pass	24794	Pass	24795	Pass	24796	Pass
24797	Pass	24798	Pass	24799	Pass	24800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



SIHOR
(GUJARAT)

Authorized Signatory