

HELIUM LEAK DETECTION TEST

TC No.: HLD/A2/K/HQ/011/26

Model No.: KFKHQ-2

Date: 27-05-2026

Type and Capacity of Extinguisher : KFKHQ-2-Kanex F Class Kitchen Fire Extinguisher Cap. 2 Ltr.

Batch Number : KFKHQ2 011/26

Batch Quantity : 10 Nos.

Serial Numbers : 00101 To 110

Month of Manufacturing : May/26

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
101	Pass	102	Pass	103	Pass	104	Pass
105	Pass	106	Pass	107	Pass	108	Pass
109	Pass	110	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**