

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/234/26	Model No.: MARQ-6-50%	Date: 09-06-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 234/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 23301 To 23400 And 23305A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 23305A and removed from the Lot/Batch							
23301	Pass	23302	Pass	23303	Pass	23304	Pass
23305	Pass	23306	Pass	23307	Pass	23308	Pass
23309	Pass	23310	Pass	23311	Pass	23312	Pass
23313	Pass	23314	Pass	23315	Pass	23316	Pass
23317	Pass	23318	Pass	23319	Pass	23320	Pass
23321	Pass	23322	Pass	23323	Pass	23324	Pass
23325	Pass	23326	Pass	23327	Pass	23328	Pass
23329	Pass	23330	Pass	23331	Pass	23332	Pass
23333	Pass	23334	Pass	23335	Pass	23336	Pass
23337	Pass	23338	Pass	23339	Pass	23340	Pass
23341	Pass	23342	Pass	23343	Pass	23344	Pass
23345	Pass	23346	Pass	23347	Pass	23348	Pass
23349	Pass	23350	Pass	23351	Pass	23352	Pass
23353	Pass	23354	Pass	23355	Pass	23356	Pass
23357	Pass	23358	Pass	23359	Pass	23360	Pass
23361	Pass	23362	Pass	23363	Pass	23364	Pass
23365	Pass	23366	Pass	23367	Pass	23368	Pass
23369	Pass	23370	Pass	23371	Pass	23372	Pass
23373	Pass	23374	Pass	23375	Pass	23376	Pass
23377	Pass	23378	Pass	23379	Pass	23380	Pass
23381	Pass	23382	Pass	23383	Pass	23384	Pass
23385	Pass	23386	Pass	23387	Pass	23388	Pass
23389	Pass	23390	Pass	23391	Pass	23392	Pass
23393	Pass	23394	Pass	23395	Pass	23396	Pass
23397	Pass	23398	Pass	23399	Pass	23400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.


 SIHOR
 (GUJARAT)

Authorized Signatory