

HELIUM LEAK DETECTION TEST

TC No.: HLD/A4/A50/SS/HQ/013/26

Model No.: KFASSHQ-4-50%

Date: 06-07-2026

Type and Capacity of Extinguisher : KFASSHQ-4-50%-Kanex ABC Dry Powder SS Fire Extinguisher Cap. 4 Kg.

Batch Number : KFASSHQ50%4 013/26

Batch Quantity : 10 Nos.

Serial Numbers : 00121 To 130

Month of Manufacturing : Jul/26

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
121	Pass	122	Pass	123	Pass	124	Pass
125	Pass	126	Pass	127	Pass	128	Pass
129	Pass	130	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**