

# HYDRO PRESSURE TEST

|                                   |                                                                      |                  |
|-----------------------------------|----------------------------------------------------------------------|------------------|
| TC No.: HPT/A4/A50/SS/HQ/013/26   | Model No.: KFASSHQ-4-50%                                             | Date: 04-07-2026 |
| Type and Capacity of Extinguisher | : KFASSHQ-4-50%-Kanex ABC Dry Powder SS Fire Extinguisher Cap. 4 Kg. |                  |
| Batch Number                      | : KFASSHQ50%4 013/26                                                 |                  |
| Batch Quantity                    | : 11.00 Nos.                                                         |                  |
| Serial Numbers                    | : 00121 To 130 And 125A                                              |                  |
| Month of Manufacturing            | : Jul/26                                                             |                  |

| Sr. Nos.                                                    | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|-------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 125A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 121                                                         | Pass   | 122      | Pass   | 123      | Pass   | 124      | Pass   |
| 125                                                         | Pass   | 126      | Pass   | 127      | Pass   | 128      | Pass   |
| 129                                                         | Pass   | 130      | Pass   |          |        |          |        |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



**Authorized Signatory**