

HYDRO PRESSURE TEST

TC No.: HPT/A4/A50/SS/HQ/014/26	Model No.: KFASSHQ-4-50%	Date: 04-07-2026
Type and Capacity of Extinguisher	: KFASSHQ-4-50%-Kanex ABC Dry Powder SS Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFASSHQ50%4 014/26	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00131 To 140 And 135A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 135A and removed from the Lot/Batch							
131	Pass	132	Pass	133	Pass	134	Pass
135	Pass	136	Pass	137	Pass	138	Pass
139	Pass	140	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory