

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/167/26	Model No.: KFARQ-6-90%	Date: 26-06-2026
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 167/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 16601 To 16700 And 16605A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 16605A and removed from the Lot/Batch							
16601	Pass	16602	Pass	16603	Pass	16604	Pass
16605	Pass	16606	Pass	16607	Pass	16608	Pass
16609	Pass	16610	Pass	16611	Pass	16612	Pass
16613	Pass	16614	Pass	16615	Pass	16616	Pass
16617	Pass	16618	Pass	16619	Pass	16620	Pass
16621	Pass	16622	Pass	16623	Pass	16624	Pass
16625	Pass	16626	Pass	16627	Pass	16628	Pass
16629	Pass	16630	Pass	16631	Pass	16632	Pass
16633	Pass	16634	Pass	16635	Pass	16636	Pass
16637	Pass	16638	Pass	16639	Pass	16640	Pass
16641	Pass	16642	Pass	16643	Pass	16644	Pass
16645	Pass	16646	Pass	16647	Pass	16648	Pass
16649	Pass	16650	Pass	16651	Pass	16652	Pass
16653	Pass	16654	Pass	16655	Pass	16656	Pass
16657	Pass	16658	Pass	16659	Pass	16660	Pass
16661	Pass	16662	Pass	16663	Pass	16664	Pass
16665	Pass	16666	Pass	16667	Pass	16668	Pass
16669	Pass	16670	Pass	16671	Pass	16672	Pass
16673	Pass	16674	Pass	16675	Pass	16676	Pass
16677	Pass	16678	Pass	16679	Pass	16680	Pass
16681	Pass	16682	Pass	16683	Pass	16684	Pass
16685	Pass	16686	Pass	16687	Pass	16688	Pass
16689	Pass	16690	Pass	16691	Pass	16692	Pass
16693	Pass	16694	Pass	16695	Pass	16696	Pass
16697	Pass	16698	Pass	16699	Pass	16700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory