

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/246/26	Model No.: MARQ-6-50%	Date: 12-06-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 246/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 24501 To 24600 And 24505A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 24505A and removed from the Lot/Batch							
24501	Pass	24502	Pass	24503	Pass	24504	Pass
24505	Pass	24506	Pass	24507	Pass	24508	Pass
24509	Pass	24510	Pass	24511	Pass	24512	Pass
24513	Pass	24514	Pass	24515	Pass	24516	Pass
24517	Pass	24518	Pass	24519	Pass	24520	Pass
24521	Pass	24522	Pass	24523	Pass	24524	Pass
24525	Pass	24526	Pass	24527	Pass	24528	Pass
24529	Pass	24530	Pass	24531	Pass	24532	Pass
24533	Pass	24534	Pass	24535	Pass	24536	Pass
24537	Pass	24538	Pass	24539	Pass	24540	Pass
24541	Pass	24542	Pass	24543	Pass	24544	Pass
24545	Pass	24546	Pass	24547	Pass	24548	Pass
24549	Pass	24550	Pass	24551	Pass	24552	Pass
24553	Pass	24554	Pass	24555	Pass	24556	Pass
24557	Pass	24558	Pass	24559	Pass	24560	Pass
24561	Pass	24562	Pass	24563	Pass	24564	Pass
24565	Pass	24566	Pass	24567	Pass	24568	Pass
24569	Pass	24570	Pass	24571	Pass	24572	Pass
24573	Pass	24574	Pass	24575	Pass	24576	Pass
24577	Pass	24578	Pass	24579	Pass	24580	Pass
24581	Pass	24582	Pass	24583	Pass	24584	Pass
24585	Pass	24586	Pass	24587	Pass	24588	Pass
24589	Pass	24590	Pass	24591	Pass	24592	Pass
24593	Pass	24594	Pass	24595	Pass	24596	Pass
24597	Pass	24598	Pass	24599	Pass	24600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory