

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/MA6/A40/RQ/247/26     | Model No.: MARQ-6-50%                                          | Date: 12-06-2026 |
| Type and Capacity of Extinguisher | : MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : MARQ50%6 247/26                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                  |                  |
| Serial Numbers                    | : 24601 To 24700 And 24605A                                    |                  |
| Month of Manufacturing            | : Jun/26                                                       |                  |

| Sr. Nos.                                                      | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|---------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 24605A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 24601                                                         | Pass   | 24602    | Pass   | 24603    | Pass   | 24604    | Pass   |
| 24605                                                         | Pass   | 24606    | Pass   | 24607    | Pass   | 24608    | Pass   |
| 24609                                                         | Pass   | 24610    | Pass   | 24611    | Pass   | 24612    | Pass   |
| 24613                                                         | Pass   | 24614    | Pass   | 24615    | Pass   | 24616    | Pass   |
| 24617                                                         | Pass   | 24618    | Pass   | 24619    | Pass   | 24620    | Pass   |
| 24621                                                         | Pass   | 24622    | Pass   | 24623    | Pass   | 24624    | Pass   |
| 24625                                                         | Pass   | 24626    | Pass   | 24627    | Pass   | 24628    | Pass   |
| 24629                                                         | Pass   | 24630    | Pass   | 24631    | Pass   | 24632    | Pass   |
| 24633                                                         | Pass   | 24634    | Pass   | 24635    | Pass   | 24636    | Pass   |
| 24637                                                         | Pass   | 24638    | Pass   | 24639    | Pass   | 24640    | Pass   |
| 24641                                                         | Pass   | 24642    | Pass   | 24643    | Pass   | 24644    | Pass   |
| 24645                                                         | Pass   | 24646    | Pass   | 24647    | Pass   | 24648    | Pass   |
| 24649                                                         | Pass   | 24650    | Pass   | 24651    | Pass   | 24652    | Pass   |
| 24653                                                         | Pass   | 24654    | Pass   | 24655    | Pass   | 24656    | Pass   |
| 24657                                                         | Pass   | 24658    | Pass   | 24659    | Pass   | 24660    | Pass   |
| 24661                                                         | Pass   | 24662    | Pass   | 24663    | Pass   | 24664    | Pass   |
| 24665                                                         | Pass   | 24666    | Pass   | 24667    | Pass   | 24668    | Pass   |
| 24669                                                         | Pass   | 24670    | Pass   | 24671    | Pass   | 24672    | Pass   |
| 24673                                                         | Pass   | 24674    | Pass   | 24675    | Pass   | 24676    | Pass   |
| 24677                                                         | Pass   | 24678    | Pass   | 24679    | Pass   | 24680    | Pass   |
| 24681                                                         | Pass   | 24682    | Pass   | 24683    | Pass   | 24684    | Pass   |
| 24685                                                         | Pass   | 24686    | Pass   | 24687    | Pass   | 24688    | Pass   |
| 24689                                                         | Pass   | 24690    | Pass   | 24691    | Pass   | 24692    | Pass   |
| 24693                                                         | Pass   | 24694    | Pass   | 24695    | Pass   | 24696    | Pass   |
| 24697                                                         | Pass   | 24698    | Pass   | 24699    | Pass   | 24700    | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



SIHOR  
(GUJARAT)

**Authorized Signatory**