

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/088/26	Model No.: KMCRQ-10	Date: 04-07-2026
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 088/26	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00871 To 880	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00871 To 880 and removed from the Lot/Batch							
871	Pass	872	Pass	873	Pass	874	Pass
875	Pass	876	Pass	877	Pass	878	Pass
879	Pass	880	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory