

HYDRO PRESSURE TEST

TC No.: HPT/A4/A50/RQ/053/26	Model No.: KFARQ-4-50%	Date: 03-07-2026
Type and Capacity of Extinguisher	: KFARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ50%4 053/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 05201 To 5300 And 5205A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 5205A and removed from the Lot/Batch							
5201	Pass	5202	Pass	5203	Pass	5204	Pass
5205	Pass	5206	Pass	5207	Pass	5208	Pass
5209	Pass	5210	Pass	5211	Pass	5212	Pass
5213	Pass	5214	Pass	5215	Pass	5216	Pass
5217	Pass	5218	Pass	5219	Pass	5220	Pass
5221	Pass	5222	Pass	5223	Pass	5224	Pass
5225	Pass	5226	Pass	5227	Pass	5228	Pass
5229	Pass	5230	Pass	5231	Pass	5232	Pass
5233	Pass	5234	Pass	5235	Pass	5236	Pass
5237	Pass	5238	Pass	5239	Pass	5240	Pass
5241	Pass	5242	Pass	5243	Pass	5244	Pass
5245	Pass	5246	Pass	5247	Pass	5248	Pass
5249	Pass	5250	Pass	5251	Pass	5252	Pass
5253	Pass	5254	Pass	5255	Pass	5256	Pass
5257	Pass	5258	Pass	5259	Pass	5260	Pass
5261	Pass	5262	Pass	5263	Pass	5264	Pass
5265	Pass	5266	Pass	5267	Pass	5268	Pass
5269	Pass	5270	Pass	5271	Pass	5272	Pass
5273	Pass	5274	Pass	5275	Pass	5276	Pass
5277	Pass	5278	Pass	5279	Pass	5280	Pass
5281	Pass	5282	Pass	5283	Pass	5284	Pass
5285	Pass	5286	Pass	5287	Pass	5288	Pass
5289	Pass	5290	Pass	5291	Pass	5292	Pass
5293	Pass	5294	Pass	5295	Pass	5296	Pass
5297	Pass	5298	Pass	5299	Pass	5300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory