

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/121/26	Model No.: MARQ-6-40%	Date: 14-05-2026
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 121/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 12001 To 12100 And 12005A	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 12005A and removed from the Lot/Batch							
12001	Pass	12002	Pass	12003	Pass	12004	Pass
12005	Pass	12006	Pass	12007	Pass	12008	Pass
12009	Pass	12010	Pass	12011	Pass	12012	Pass
12013	Pass	12014	Pass	12015	Pass	12016	Pass
12017	Pass	12018	Pass	12019	Pass	12020	Pass
12021	Pass	12022	Pass	12023	Pass	12024	Pass
12025	Pass	12026	Pass	12027	Pass	12028	Pass
12029	Pass	12030	Pass	12031	Pass	12032	Pass
12033	Pass	12034	Pass	12035	Pass	12036	Pass
12037	Pass	12038	Pass	12039	Pass	12040	Pass
12041	Pass	12042	Pass	12043	Pass	12044	Pass
12045	Pass	12046	Pass	12047	Pass	12048	Pass
12049	Pass	12050	Pass	12051	Pass	12052	Pass
12053	Pass	12054	Pass	12055	Pass	12056	Pass
12057	Pass	12058	Pass	12059	Pass	12060	Pass
12061	Pass	12062	Pass	12063	Pass	12064	Pass
12065	Pass	12066	Pass	12067	Pass	12068	Pass
12069	Pass	12070	Pass	12071	Pass	12072	Pass
12073	Pass	12074	Pass	12075	Pass	12076	Pass
12077	Pass	12078	Pass	12079	Pass	12080	Pass
12081	Pass	12082	Pass	12083	Pass	12084	Pass
12085	Pass	12086	Pass	12087	Pass	12088	Pass
12089	Pass	12090	Pass	12091	Pass	12092	Pass
12093	Pass	12094	Pass	12095	Pass	12096	Pass
12097	Pass	12098	Pass	12099	Pass	12100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.


 A circular purple stamp with the text "SIHOR (GUJARAT)" in the center and "KANEX FIRE SOLUTIONS LIMITED" around the perimeter. A signature is written over the stamp.

Authorized Signatory