

# HYDRO PRESSURE TEST

|                                   |                                                                    |                  |
|-----------------------------------|--------------------------------------------------------------------|------------------|
| TC No.: HPT/CA6/RQ/012/26         | Model No.: KCARQ-6                                                 | Date: 12-06-2026 |
| Type and Capacity of Extinguisher | : KCARQ-6-Kanex Clean Agent HFC Based Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : KCARQ6 012/26                                                    |                  |
| Batch Quantity                    | : 101.00 Nos.                                                      |                  |
| Serial Numbers                    | : 01101 To 1200 And 1105A                                          |                  |
| Month of Manufacturing            | : Jun/26                                                           |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 1105A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 1101                                                         | Pass   | 1102     | Pass   | 1103     | Pass   | 1104     | Pass   |
| 1105                                                         | Pass   | 1106     | Pass   | 1107     | Pass   | 1108     | Pass   |
| 1109                                                         | Pass   | 1110     | Pass   | 1111     | Pass   | 1112     | Pass   |
| 1113                                                         | Pass   | 1114     | Pass   | 1115     | Pass   | 1116     | Pass   |
| 1117                                                         | Pass   | 1118     | Pass   | 1119     | Pass   | 1120     | Pass   |
| 1121                                                         | Pass   | 1122     | Pass   | 1123     | Pass   | 1124     | Pass   |
| 1125                                                         | Pass   | 1126     | Pass   | 1127     | Pass   | 1128     | Pass   |
| 1129                                                         | Pass   | 1130     | Pass   | 1131     | Pass   | 1132     | Pass   |
| 1133                                                         | Pass   | 1134     | Pass   | 1135     | Pass   | 1136     | Pass   |
| 1137                                                         | Pass   | 1138     | Pass   | 1139     | Pass   | 1140     | Pass   |
| 1141                                                         | Pass   | 1142     | Pass   | 1143     | Pass   | 1144     | Pass   |
| 1145                                                         | Pass   | 1146     | Pass   | 1147     | Pass   | 1148     | Pass   |
| 1149                                                         | Pass   | 1150     | Pass   | 1151     | Pass   | 1152     | Pass   |
| 1153                                                         | Pass   | 1154     | Pass   | 1155     | Pass   | 1156     | Pass   |
| 1157                                                         | Pass   | 1158     | Pass   | 1159     | Pass   | 1160     | Pass   |
| 1161                                                         | Pass   | 1162     | Pass   | 1163     | Pass   | 1164     | Pass   |
| 1165                                                         | Pass   | 1166     | Pass   | 1167     | Pass   | 1168     | Pass   |
| 1169                                                         | Pass   | 1170     | Pass   | 1171     | Pass   | 1172     | Pass   |
| 1173                                                         | Pass   | 1174     | Pass   | 1175     | Pass   | 1176     | Pass   |
| 1177                                                         | Pass   | 1178     | Pass   | 1179     | Pass   | 1180     | Pass   |
| 1181                                                         | Pass   | 1182     | Pass   | 1183     | Pass   | 1184     | Pass   |
| 1185                                                         | Pass   | 1186     | Pass   | 1187     | Pass   | 1188     | Pass   |
| 1189                                                         | Pass   | 1190     | Pass   | 1191     | Pass   | 1192     | Pass   |
| 1193                                                         | Pass   | 1194     | Pass   | 1195     | Pass   | 1196     | Pass   |
| 1197                                                         | Pass   | 1198     | Pass   | 1199     | Pass   | 1200     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**