

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/214/26	Model No.: KFARQ-6-50%	Date: 03-07-2026
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 214/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 21301 To 21400 And 21305A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 21305A and removed from the Lot/Batch							
21301	Pass	21302	Pass	21303	Pass	21304	Pass
21305	Pass	21306	Pass	21307	Pass	21308	Pass
21309	Pass	21310	Pass	21311	Pass	21312	Pass
21313	Pass	21314	Pass	21315	Pass	21316	Pass
21317	Pass	21318	Pass	21319	Pass	21320	Pass
21321	Pass	21322	Pass	21323	Pass	21324	Pass
21325	Pass	21326	Pass	21327	Pass	21328	Pass
21329	Pass	21330	Pass	21331	Pass	21332	Pass
21333	Pass	21334	Pass	21335	Pass	21336	Pass
21337	Pass	21338	Pass	21339	Pass	21340	Pass
21341	Pass	21342	Pass	21343	Pass	21344	Pass
21345	Pass	21346	Pass	21347	Pass	21348	Pass
21349	Pass	21350	Pass	21351	Pass	21352	Pass
21353	Pass	21354	Pass	21355	Pass	21356	Pass
21357	Pass	21358	Pass	21359	Pass	21360	Pass
21361	Pass	21362	Pass	21363	Pass	21364	Pass
21365	Pass	21366	Pass	21367	Pass	21368	Pass
21369	Pass	21370	Pass	21371	Pass	21372	Pass
21373	Pass	21374	Pass	21375	Pass	21376	Pass
21377	Pass	21378	Pass	21379	Pass	21380	Pass
21381	Pass	21382	Pass	21383	Pass	21384	Pass
21385	Pass	21386	Pass	21387	Pass	21388	Pass
21389	Pass	21390	Pass	21391	Pass	21392	Pass
21393	Pass	21394	Pass	21395	Pass	21396	Pass
21397	Pass	21398	Pass	21399	Pass	21400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory