

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/215/26	Model No.: KFARQ-6-50%	Date: 03-07-2026
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 215/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 21401 To 21500 And 21405A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 21405A and removed from the Lot/Batch							
21401	Pass	21402	Pass	21403	Pass	21404	Pass
21405	Pass	21406	Pass	21407	Pass	21408	Pass
21409	Pass	21410	Pass	21411	Pass	21412	Pass
21413	Pass	21414	Pass	21415	Pass	21416	Pass
21417	Pass	21418	Pass	21419	Pass	21420	Pass
21421	Pass	21422	Pass	21423	Pass	21424	Pass
21425	Pass	21426	Pass	21427	Pass	21428	Pass
21429	Pass	21430	Pass	21431	Pass	21432	Pass
21433	Pass	21434	Pass	21435	Pass	21436	Pass
21437	Pass	21438	Pass	21439	Pass	21440	Pass
21441	Pass	21442	Pass	21443	Pass	21444	Pass
21445	Pass	21446	Pass	21447	Pass	21448	Pass
21449	Pass	21450	Pass	21451	Pass	21452	Pass
21453	Pass	21454	Pass	21455	Pass	21456	Pass
21457	Pass	21458	Pass	21459	Pass	21460	Pass
21461	Pass	21462	Pass	21463	Pass	21464	Pass
21465	Pass	21466	Pass	21467	Pass	21468	Pass
21469	Pass	21470	Pass	21471	Pass	21472	Pass
21473	Pass	21474	Pass	21475	Pass	21476	Pass
21477	Pass	21478	Pass	21479	Pass	21480	Pass
21481	Pass	21482	Pass	21483	Pass	21484	Pass
21485	Pass	21486	Pass	21487	Pass	21488	Pass
21489	Pass	21490	Pass	21491	Pass	21492	Pass
21493	Pass	21494	Pass	21495	Pass	21496	Pass
21497	Pass	21498	Pass	21499	Pass	21500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory