

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/129/26	Model No.: KFARQ-4-90%	Date: 02-06-2026
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 129/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 12801 To 12900 And 12805A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 12805A and removed from the Lot/Batch							
12801	Pass	12802	Pass	12803	Pass	12804	Pass
12805	Pass	12806	Pass	12807	Pass	12808	Pass
12809	Pass	12810	Pass	12811	Pass	12812	Pass
12813	Pass	12814	Pass	12815	Pass	12816	Pass
12817	Pass	12818	Pass	12819	Pass	12820	Pass
12821	Pass	12822	Pass	12823	Pass	12824	Pass
12825	Pass	12826	Pass	12827	Pass	12828	Pass
12829	Pass	12830	Pass	12831	Pass	12832	Pass
12833	Pass	12834	Pass	12835	Pass	12836	Pass
12837	Pass	12838	Pass	12839	Pass	12840	Pass
12841	Pass	12842	Pass	12843	Pass	12844	Pass
12845	Pass	12846	Pass	12847	Pass	12848	Pass
12849	Pass	12850	Pass	12851	Pass	12852	Pass
12853	Pass	12854	Pass	12855	Pass	12856	Pass
12857	Pass	12858	Pass	12859	Pass	12860	Pass
12861	Pass	12862	Pass	12863	Pass	12864	Pass
12865	Pass	12866	Pass	12867	Pass	12868	Pass
12869	Pass	12870	Pass	12871	Pass	12872	Pass
12873	Pass	12874	Pass	12875	Pass	12876	Pass
12877	Pass	12878	Pass	12879	Pass	12880	Pass
12881	Pass	12882	Pass	12883	Pass	12884	Pass
12885	Pass	12886	Pass	12887	Pass	12888	Pass
12889	Pass	12890	Pass	12891	Pass	12892	Pass
12893	Pass	12894	Pass	12895	Pass	12896	Pass
12897	Pass	12898	Pass	12899	Pass	12900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.


 SIHOR
 (GUJARAT)

Authorized Signatory