

HELIUM LEAK DETECTION TEST

TC No.: HLD/A6/K/HQ/102/26	Model No.: KFKHQ-6	Date: 05-07-2026
Type and Capacity of Extinguisher	: KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFKHQ6 102/26	
Batch Quantity	: 10 Nos.	
Serial Numbers	: 01011 To 1020	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
1011	Pass	1012	Pass	1013	Pass	1014	Pass
1015	Pass	1016	Pass	1017	Pass	1018	Pass
1019	Pass	1020	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.



Authorized Signatory