

HYDRO PRESSURE TEST

TC No.: HPT/A9/A90/RQ/040/26	Model No.: KFARQ-9-90%	Date: 26-05-2026
Type and Capacity of Extinguisher	: KFARQ-9-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 9 Kg.	
Batch Number	: KFARQ90%9 040/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 03901 To 4000 And 3905A	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 3905A and removed from the Lot/Batch							
3901	Pass	3902	Pass	3903	Pass	3904	Pass
3905	Pass	3906	Pass	3907	Pass	3908	Pass
3909	Pass	3910	Pass	3911	Pass	3912	Pass
3913	Pass	3914	Pass	3915	Pass	3916	Pass
3917	Pass	3918	Pass	3919	Pass	3920	Pass
3921	Pass	3922	Pass	3923	Pass	3924	Pass
3925	Pass	3926	Pass	3927	Pass	3928	Pass
3929	Pass	3930	Pass	3931	Pass	3932	Pass
3933	Pass	3934	Pass	3935	Pass	3936	Pass
3937	Pass	3938	Pass	3939	Pass	3940	Pass
3941	Pass	3942	Pass	3943	Pass	3944	Pass
3945	Pass	3946	Pass	3947	Pass	3948	Pass
3949	Pass	3950	Pass	3951	Pass	3952	Pass
3953	Pass	3954	Pass	3955	Pass	3956	Pass
3957	Pass	3958	Pass	3959	Pass	3960	Pass
3961	Pass	3962	Pass	3963	Pass	3964	Pass
3965	Pass	3966	Pass	3967	Pass	3968	Pass
3969	Pass	3970	Pass	3971	Pass	3972	Pass
3973	Pass	3974	Pass	3975	Pass	3976	Pass
3977	Pass	3978	Pass	3979	Pass	3980	Pass
3981	Pass	3982	Pass	3983	Pass	3984	Pass
3985	Pass	3986	Pass	3987	Pass	3988	Pass
3989	Pass	3990	Pass	3991	Pass	3992	Pass
3993	Pass	3994	Pass	3995	Pass	3996	Pass
3997	Pass	3998	Pass	3999	Pass	4000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory