

HYDRO PRESSURE TEST

TC No.: HPT/A6/K/HQ/090/26	Model No.: KFKHQ-6	Date: 07-06-2026
Type and Capacity of Extinguisher	: KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFKHQ6 090/26	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00891 To 900 And 895A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 895A and removed from the Lot/Batch							
891	Pass	892	Pass	893	Pass	894	Pass
895	Pass	896	Pass	897	Pass	898	Pass
899	Pass	900	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory