

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/151/26	Model No.: KFARQ-6-90%	Date: 19-06-2026
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 151/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 15001 To 15100 And 15005A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 15005A and removed from the Lot/Batch							
15001	Pass	15002	Pass	15003	Pass	15004	Pass
15005	Pass	15006	Pass	15007	Pass	15008	Pass
15009	Pass	15010	Pass	15011	Pass	15012	Pass
15013	Pass	15014	Pass	15015	Pass	15016	Pass
15017	Pass	15018	Pass	15019	Pass	15020	Pass
15021	Pass	15022	Pass	15023	Pass	15024	Pass
15025	Pass	15026	Pass	15027	Pass	15028	Pass
15029	Pass	15030	Pass	15031	Pass	15032	Pass
15033	Pass	15034	Pass	15035	Pass	15036	Pass
15037	Pass	15038	Pass	15039	Pass	15040	Pass
15041	Pass	15042	Pass	15043	Pass	15044	Pass
15045	Pass	15046	Pass	15047	Pass	15048	Pass
15049	Pass	15050	Pass	15051	Pass	15052	Pass
15053	Pass	15054	Pass	15055	Pass	15056	Pass
15057	Pass	15058	Pass	15059	Pass	15060	Pass
15061	Pass	15062	Pass	15063	Pass	15064	Pass
15065	Pass	15066	Pass	15067	Pass	15068	Pass
15069	Pass	15070	Pass	15071	Pass	15072	Pass
15073	Pass	15074	Pass	15075	Pass	15076	Pass
15077	Pass	15078	Pass	15079	Pass	15080	Pass
15081	Pass	15082	Pass	15083	Pass	15084	Pass
15085	Pass	15086	Pass	15087	Pass	15088	Pass
15089	Pass	15090	Pass	15091	Pass	15092	Pass
15093	Pass	15094	Pass	15095	Pass	15096	Pass
15097	Pass	15098	Pass	15099	Pass	15100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.


 A circular purple stamp with the text "SIHOR (GUJARAT)" in the center and "KANEX FIRE SOLUTIONS LIMITED" around the perimeter. A signature is written over the stamp.

Authorized Signatory