

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/152/26	Model No.: KFARQ-6-90%	Date: 19-06-2026
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 152/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 15101 To 15200 And 15105A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 15105A and removed from the Lot/Batch							
15101	Pass	15102	Pass	15103	Pass	15104	Pass
15105	Pass	15106	Pass	15107	Pass	15108	Pass
15109	Pass	15110	Pass	15111	Pass	15112	Pass
15113	Pass	15114	Pass	15115	Pass	15116	Pass
15117	Pass	15118	Pass	15119	Pass	15120	Pass
15121	Pass	15122	Pass	15123	Pass	15124	Pass
15125	Pass	15126	Pass	15127	Pass	15128	Pass
15129	Pass	15130	Pass	15131	Pass	15132	Pass
15133	Pass	15134	Pass	15135	Pass	15136	Pass
15137	Pass	15138	Pass	15139	Pass	15140	Pass
15141	Pass	15142	Pass	15143	Pass	15144	Pass
15145	Pass	15146	Pass	15147	Pass	15148	Pass
15149	Pass	15150	Pass	15151	Pass	15152	Pass
15153	Pass	15154	Pass	15155	Pass	15156	Pass
15157	Pass	15158	Pass	15159	Pass	15160	Pass
15161	Pass	15162	Pass	15163	Pass	15164	Pass
15165	Pass	15166	Pass	15167	Pass	15168	Pass
15169	Pass	15170	Pass	15171	Pass	15172	Pass
15173	Pass	15174	Pass	15175	Pass	15176	Pass
15177	Pass	15178	Pass	15179	Pass	15180	Pass
15181	Pass	15182	Pass	15183	Pass	15184	Pass
15185	Pass	15186	Pass	15187	Pass	15188	Pass
15189	Pass	15190	Pass	15191	Pass	15192	Pass
15193	Pass	15194	Pass	15195	Pass	15196	Pass
15197	Pass	15198	Pass	15199	Pass	15200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory