

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A50/RQ/028/26	Model No.: MARQ-9-50%	Date: 25-06-2026
Type and Capacity of Extinguisher	: MARQ-9-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 9 Kg.	
Batch Number	: MARQ50%9 028/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 02701 To 2800 And 2705A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 2705A and removed from the Lot/Batch							
2701	Pass	2702	Pass	2703	Pass	2704	Pass
2705	Pass	2706	Pass	2707	Pass	2708	Pass
2709	Pass	2710	Pass	2711	Pass	2712	Pass
2713	Pass	2714	Pass	2715	Pass	2716	Pass
2717	Pass	2718	Pass	2719	Pass	2720	Pass
2721	Pass	2722	Pass	2723	Pass	2724	Pass
2725	Pass	2726	Pass	2727	Pass	2728	Pass
2729	Pass	2730	Pass	2731	Pass	2732	Pass
2733	Pass	2734	Pass	2735	Pass	2736	Pass
2737	Pass	2738	Pass	2739	Pass	2740	Pass
2741	Pass	2742	Pass	2743	Pass	2744	Pass
2745	Pass	2746	Pass	2747	Pass	2748	Pass
2749	Pass	2750	Pass	2751	Pass	2752	Pass
2753	Pass	2754	Pass	2755	Pass	2756	Pass
2757	Pass	2758	Pass	2759	Pass	2760	Pass
2761	Pass	2762	Pass	2763	Pass	2764	Pass
2765	Pass	2766	Pass	2767	Pass	2768	Pass
2769	Pass	2770	Pass	2771	Pass	2772	Pass
2773	Pass	2774	Pass	2775	Pass	2776	Pass
2777	Pass	2778	Pass	2779	Pass	2780	Pass
2781	Pass	2782	Pass	2783	Pass	2784	Pass
2785	Pass	2786	Pass	2787	Pass	2788	Pass
2789	Pass	2790	Pass	2791	Pass	2792	Pass
2793	Pass	2794	Pass	2795	Pass	2796	Pass
2797	Pass	2798	Pass	2799	Pass	2800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory