

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/221/26	Model No.: KFARQ-6-50%	Date: 04-07-2026
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 221/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 22001 To 22100 And 22005A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 22005A and removed from the Lot/Batch							
22001	Pass	22002	Pass	22003	Pass	22004	Pass
22005	Pass	22006	Pass	22007	Pass	22008	Pass
22009	Pass	22010	Pass	22011	Pass	22012	Pass
22013	Pass	22014	Pass	22015	Pass	22016	Pass
22017	Pass	22018	Pass	22019	Pass	22020	Pass
22021	Pass	22022	Pass	22023	Pass	22024	Pass
22025	Pass	22026	Pass	22027	Pass	22028	Pass
22029	Pass	22030	Pass	22031	Pass	22032	Pass
22033	Pass	22034	Pass	22035	Pass	22036	Pass
22037	Pass	22038	Pass	22039	Pass	22040	Pass
22041	Pass	22042	Pass	22043	Pass	22044	Pass
22045	Pass	22046	Pass	22047	Pass	22048	Pass
22049	Pass	22050	Pass	22051	Pass	22052	Pass
22053	Pass	22054	Pass	22055	Pass	22056	Pass
22057	Pass	22058	Pass	22059	Pass	22060	Pass
22061	Pass	22062	Pass	22063	Pass	22064	Pass
22065	Pass	22066	Pass	22067	Pass	22068	Pass
22069	Pass	22070	Pass	22071	Pass	22072	Pass
22073	Pass	22074	Pass	22075	Pass	22076	Pass
22077	Pass	22078	Pass	22079	Pass	22080	Pass
22081	Pass	22082	Pass	22083	Pass	22084	Pass
22085	Pass	22086	Pass	22087	Pass	22088	Pass
22089	Pass	22090	Pass	22091	Pass	22092	Pass
22093	Pass	22094	Pass	22095	Pass	22096	Pass
22097	Pass	22098	Pass	22099	Pass	22100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory