

# HYDRO PRESSURE TEST

|                                   |                                                                 |                  |
|-----------------------------------|-----------------------------------------------------------------|------------------|
| TC No.: HPT/A6/A50/RQ/173/26      | Model No.: KFARQ-6-50%                                          | Date: 18-05-2026 |
| Type and Capacity of Extinguisher | : KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : KFARQ50%6 173/26                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                   |                  |
| Serial Numbers                    | : 17201 To 17300 And 17205A                                     |                  |
| Month of Manufacturing            | : May/26                                                        |                  |

| Sr. Nos.                                                      | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|---------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 17205A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 17201                                                         | Pass   | 17202    | Pass   | 17203    | Pass   | 17204    | Pass   |
| 17205                                                         | Pass   | 17206    | Pass   | 17207    | Pass   | 17208    | Pass   |
| 17209                                                         | Pass   | 17210    | Pass   | 17211    | Pass   | 17212    | Pass   |
| 17213                                                         | Pass   | 17214    | Pass   | 17215    | Pass   | 17216    | Pass   |
| 17217                                                         | Pass   | 17218    | Pass   | 17219    | Pass   | 17220    | Pass   |
| 17221                                                         | Pass   | 17222    | Pass   | 17223    | Pass   | 17224    | Pass   |
| 17225                                                         | Pass   | 17226    | Pass   | 17227    | Pass   | 17228    | Pass   |
| 17229                                                         | Pass   | 17230    | Pass   | 17231    | Pass   | 17232    | Pass   |
| 17233                                                         | Pass   | 17234    | Pass   | 17235    | Pass   | 17236    | Pass   |
| 17237                                                         | Pass   | 17238    | Pass   | 17239    | Pass   | 17240    | Pass   |
| 17241                                                         | Pass   | 17242    | Pass   | 17243    | Pass   | 17244    | Pass   |
| 17245                                                         | Pass   | 17246    | Pass   | 17247    | Pass   | 17248    | Pass   |
| 17249                                                         | Pass   | 17250    | Pass   | 17251    | Pass   | 17252    | Pass   |
| 17253                                                         | Pass   | 17254    | Pass   | 17255    | Pass   | 17256    | Pass   |
| 17257                                                         | Pass   | 17258    | Pass   | 17259    | Pass   | 17260    | Pass   |
| 17261                                                         | Pass   | 17262    | Pass   | 17263    | Pass   | 17264    | Pass   |
| 17265                                                         | Pass   | 17266    | Pass   | 17267    | Pass   | 17268    | Pass   |
| 17269                                                         | Pass   | 17270    | Pass   | 17271    | Pass   | 17272    | Pass   |
| 17273                                                         | Pass   | 17274    | Pass   | 17275    | Pass   | 17276    | Pass   |
| 17277                                                         | Pass   | 17278    | Pass   | 17279    | Pass   | 17280    | Pass   |
| 17281                                                         | Pass   | 17282    | Pass   | 17283    | Pass   | 17284    | Pass   |
| 17285                                                         | Pass   | 17286    | Pass   | 17287    | Pass   | 17288    | Pass   |
| 17289                                                         | Pass   | 17290    | Pass   | 17291    | Pass   | 17292    | Pass   |
| 17293                                                         | Pass   | 17294    | Pass   | 17295    | Pass   | 17296    | Pass   |
| 17297                                                         | Pass   | 17298    | Pass   | 17299    | Pass   | 17300    | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**