

HYDRO PRESSURE TEST

TC No.: HPT/W9/SP/RQ/039/24	Model No.: KFWSRQ-9	Date: 19-09-2024
Type and Capacity of Extinguisher	: KFWSRQ-9-Kanex Water SP Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: KFWSRQ9 039/24	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 03801 To 3900 And 3805A	
Month of Manufacturing	: Sep/24	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 3805A and removed from the Lot/Batch							
3801	Pass	3802	Pass	3803	Pass	3804	Pass
3805	Pass	3806	Pass	3807	Pass	3808	Pass
3809	Pass	3810	Pass	3811	Pass	3812	Pass
3813	Pass	3814	Pass	3815	Pass	3816	Pass
3817	Pass	3818	Pass	3819	Pass	3820	Pass
3821	Pass	3822	Pass	3823	Pass	3824	Pass
3825	Pass	3826	Pass	3827	Pass	3828	Pass
3829	Pass	3830	Pass	3831	Pass	3832	Pass
3833	Pass	3834	Pass	3835	Pass	3836	Pass
3837	Pass	3838	Pass	3839	Pass	3840	Pass
3841	Pass	3842	Pass	3843	Pass	3844	Pass
3845	Pass	3846	Pass	3847	Pass	3848	Pass
3849	Pass	3850	Pass	3851	Pass	3852	Pass
3853	Pass	3854	Pass	3855	Pass	3856	Pass
3857	Pass	3858	Pass	3859	Pass	3860	Pass
3861	Pass	3862	Pass	3863	Pass	3864	Pass
3865	Pass	3866	Pass	3867	Pass	3868	Pass
3869	Pass	3870	Pass	3871	Pass	3872	Pass
3873	Pass	3874	Pass	3875	Pass	3876	Pass
3877	Pass	3878	Pass	3879	Pass	3880	Pass
3881	Pass	3882	Pass	3883	Pass	3884	Pass
3885	Pass	3886	Pass	3887	Pass	3888	Pass
3889	Pass	3890	Pass	3891	Pass	3892	Pass
3893	Pass	3894	Pass	3895	Pass	3896	Pass
3897	Pass	3898	Pass	3899	Pass	3900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory