

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/269/26	Model No.: MARQ-6-50%	Date: 03-07-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 269/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 26801 To 26900 And 26805A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 26805A and removed from the Lot/Batch							
26801	Pass	26802	Pass	26803	Pass	26804	Pass
26805	Pass	26806	Pass	26807	Pass	26808	Pass
26809	Pass	26810	Pass	26811	Pass	26812	Pass
26813	Pass	26814	Pass	26815	Pass	26816	Pass
26817	Pass	26818	Pass	26819	Pass	26820	Pass
26821	Pass	26822	Pass	26823	Pass	26824	Pass
26825	Pass	26826	Pass	26827	Pass	26828	Pass
26829	Pass	26830	Pass	26831	Pass	26832	Pass
26833	Pass	26834	Pass	26835	Pass	26836	Pass
26837	Pass	26838	Pass	26839	Pass	26840	Pass
26841	Pass	26842	Pass	26843	Pass	26844	Pass
26845	Pass	26846	Pass	26847	Pass	26848	Pass
26849	Pass	26850	Pass	26851	Pass	26852	Pass
26853	Pass	26854	Pass	26855	Pass	26856	Pass
26857	Pass	26858	Pass	26859	Pass	26860	Pass
26861	Pass	26862	Pass	26863	Pass	26864	Pass
26865	Pass	26866	Pass	26867	Pass	26868	Pass
26869	Pass	26870	Pass	26871	Pass	26872	Pass
26873	Pass	26874	Pass	26875	Pass	26876	Pass
26877	Pass	26878	Pass	26879	Pass	26880	Pass
26881	Pass	26882	Pass	26883	Pass	26884	Pass
26885	Pass	26886	Pass	26887	Pass	26888	Pass
26889	Pass	26890	Pass	26891	Pass	26892	Pass
26893	Pass	26894	Pass	26895	Pass	26896	Pass
26897	Pass	26898	Pass	26899	Pass	26900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory